

MONTHLY FIRE EXTINGUISHER INSPECTION

[INSPECTION SYMBOLS ✓ = Pass ✗ = Fail]

Company: _____

Site: _____

Location: _____

Date: _____

Initial each month after completing the inspection.
P = Pass / F = Fail

- Portable Fire Extinguisher Monthly Inspection Instructions (*Simple Checklist*)**
- Pressure Gauge: Needle is in the green zone.
 - Physical Condition: No dents, rust, corrosion, or damage.
 - Hose/Nozzle: free of cracks, blockage, or debris.
 - Tamper Seal & Pin: Seal intact, pin inserted.
 - Label/Instructions: Legible and facing outward.
 - Weight/Fullness: Extinguisher feels full when lifted.
 - No Leaks: No signs of leakage or powder residue.

[January - June]

ID	Serial #	Initial	P	F	Initial	P	F	Initial	P	F	Initial	P	F	Initial	P	F
			Jan			Feb			Mar			Apr			May	

[July - December]

ID	Serial #	Initial	P	F	Initial	P	F	Initial	P	F	Initial	P	F	Initial	P	F
			Jul			Aug			Sep			Oct			Nov	